



July 1, 2009

Ms. Donna Geiger
Office of the Governor
1100 San Jacinto
Austin, Texas 78701

Mr. John O'Brien
Deputy Director
Legislative Budget Board (LBB)
Robert E. Johnson Bldg. – 5th Floor
1501 North Congress
Austin, Texas 78701

RE: RP-49, FY 2009 – 3rd Quarter Update

The Texas Tech University Health Sciences Center (TTUHSC) Energy Savings Update is being submitted in accordance with Governor's Executive Order, RP 49, Electric Conservation by State Agencies. TTUHSC continues to promote energy conservation measures and strategies and seek new ideas to reduce consumption and improve building system efficiencies.

A. Energy Consumption & Goals

Attached is Exhibit I where our 3rd Quarter FY2009 consumption breakdowns can be found. Exhibit I also includes previous quarters, overall totals for each utility and energy equivalents to facilitate comparisons between quarters and annual totals.

Additionally, Table I (Page 2) shows a breakdown for each type of utility in kBtu per square foot. The energy units were converted to kBtu to allow for comparisons of the various energy forms and then divided by the appropriate campus square footage to obtain an energy utilization index in kBtu/square foot. A negative % change indicates a decrease in consumption, while a positive number indicates an increase compared to the previous year.

In the 3rd Quarter FY2009, the campus consumed 52.88 kBtu/sq ft, an increase of 8% compared to the 3rd Quarter FY2008. Increase in energy consumption is mainly due to addition of research space and increase in overall occupancy. Texas Tech University Health Sciences Center continues to undergo significant capital improvements and steady growth, which are expected to increase the overall energy consumption. However, steam consumption per square foot has decreased by more than 22% as compared to the 3rd Quarter FY2008. Our overall institutional goal is to reduce our energy utilization index by 2.5% for the period from FY2009 to FY2013, with the base being FY2007.





Table I: Campus Energy Use (kBtu/Sq ft): March - May

Utility	FY08 Actual	FY09 Actual	% Change
Electricity	16.75	18.61	11.10 %
Nat. Gas	07.31	12.00	64.16 %
Steam	12.12	09.43	-22.20 %
Chilled Water	12.79	12.84	00.38 %
Total	48.97	52.88	07.98 %

Refer attached 'EXHIBIT 1' for further details of campus energy use.

B. Current Energy Reduction Plans

Texas Tech University Health Sciences Center has identified the following tactics and measures for potential consideration in reducing the campus energy consumption. Projects will be prioritized based on a variety of factors including return on investment, cost and availability of funding. The successful implementation and funding of these and other projects will form the basis of the energy reduction goal of 2.5% per year reduction in energy utilization index for the period of FY2009 through FY2013. Below is a partial list and status of ongoing projects that are currently being designed and evaluated.

1. Mechanical system modifications to reduce energy consumption at the Medical Science Building, El Paso. *Project in substantial completion phase.*
2. Installation of a dual duct air distribution system for TTU Health Sciences Center at El Paso to operate the air handling units according to the design intent. *Project is currently in schematic design.*
3. Implementation of centralized Computer Maintenance Management System to effectively manage operation & maintenance activities. *Project in implementation phase.*
4. Relamping to install new energy efficient T8 fluorescent lamps, to comply with the lighting power density requirement of the state energy code. *Pending funding approval.*
5. Lighting retrofit for LB Institute for Women's Health in Amarillo. *Pending funding approval.*
6. Complete installation of occupancy sensors for lighting control, and vending machine operation. *Pending funding approval.*





C. Future Energy Reduction Plans

TTUHSC has identified various energy conservation projects which are projected to cost about \$3,829,470 with an estimated payback of less than 8 years. The details of which are included in the 'Resource Efficiency Plan' in accordance with 34 TAC, Chapter 19.

D. Fuel Consumption Reduction Plans

TTUHSC continues to emphasize energy conservation awareness with strategies such as regular preventative maintenance, and an emphasis on tire pressure and conditions to gain economies.

Your consideration of this update and information is appreciated.

Sincerely,

George G. Morales, P.E.
Assistant Vice-President for Physical Plant & Support Services

Enclosure: EXHIBIT 1

XC:

1. Elmo Cavin
Executive Vice-President of Finance & Administration
2. Director, State Energy Conservation Office
Comptroller of Public Accounts
111 E. 17th Street, Suite 1114, Austin, Texas 78774





EXHIBIT I

FY2008 ACTUAL ENERGY CONSUMPTION					
<u>ENERGY</u>	<u>1st Quarter FY 2008</u>	<u>2nd Quarter FY 2008</u>	<u>3rd Quarter FY 2008</u>	<u>4th Quarter FY 2008</u>	<u>Total FY 2008</u>
ELECTRICITY, kwh	11,236,578	10,336,536	11,375,239	14,539,907	47,488,260
NATURAL GAS, ccf	185,272	277,589	164,918	143,333	771,112
STEAM, mlb	21,643	37,072	25,011	15,170	98,896
CHILLED WATER, tn-hr	<u>2,745,312</u>	<u>2,095,668</u>	<u>2,470,362</u>	<u>4,033,161</u>	<u>11,344,503</u>
THERMAL ENERGY*, mbtu	57,248,721	66,779,670	57,732,034	65,434,213	247,194,637
ENERGY EQUIVALENT, (mbtu)	<u>114,645,138</u>	<u>130,594,461</u>	<u>113,509,302</u>	<u>129,793,501</u>	<u>488,542,402</u>
*Natural Gas is used to produce the Thermal Energies of Steam and Chilled Water					-

FY2009 ACTUAL ENERGY CONSUMPTION					
<u>ENERGY</u>	<u>1st Quarter FY 2009</u>	<u>2nd Quarter FY 2009</u>	<u>3rd Quarter FY 2009</u>	<u>4th Quarter FY 2009</u>	<u>Total FY 2009</u>
ELECTRICITY, kwh	12,332,590	11,993,848	12,922,585		37,249,023
NATURAL GAS, ccf	195,297	350,110	276,546		821,953
STEAM, mlb	22,840	39,612	19,895		82,346
CHILLED WATER, tn-hr	<u>2,359,557</u>	<u>1,980,452</u>	<u>2,535,335</u>		<u>6,875,344</u>
THERMAL ENERGY*, mbtu	53,963,521	68,249,329	52,765,892		174,978,742
ENERGY EQUIVALENT, (mbtu)	<u>116,131,174</u>	<u>145,175,663</u>	<u>125,299,597</u>	<u>0</u>	<u>386,606,434</u>
*Natural Gas is used to produce the Thermal Energies of Steam and Chilled Water					-

